

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.: AEE/PHE/HKTL/2024-25/ 414

Dated: 20/12/2024


It is certified that an inspection team headed by..... Taher Ahmed Lashar.....
Designation..... Asst. Ex. Engineer..... from PHE Hailakandi Division, Hailakandi.....

inspected the **LALA CENTRAL SCHOOL, VILL-DHANIPUR, P.O-LALA, DIST.-HAILAKANDI**

on..... 20/12/2024..... and on the basis of Water Test Report (Attached) bearing
no..... PHE/DLL/HKD/DW/PS/Y24-107..... dated..... 26/11/2024.....

of District Level Laboratory (PHED Lab) certified that the **LALA CENTRAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till..... 20/12/2025.....

Signature with Seal:..... .....

Asst. Executive Engineer (PHE)

Katlicherra Sub-Division, Katlicherra

Name:..... Taher Ahmed Lashar.....


Designation:..... Asst. Executive Engineer.....


Name & Address of the Office/Department:.....

PHE Hailakandi Division, Hailakandi.....

To

LALA CENTRAL SCHOOL
VILL-DHANIPUR, P.O-LALA, DIST.-HAILAKANDI, ASSAM

Attested

Chairman
Managing Committee
Lala Central School
Hailakandi

Attested

Principal
Central School
Hailakandi



District Level Laboratory
Public Health Engineering Department
 [Government of Assam]
 Hailakandi 788155



Email ID: dllpnehkd@gmail.com

Ph. No: 9859528946

Test Report

Test Report No. : PHE/DLL /HKD/DW/PS/Y24-107 Issue Date: 26-11-24
 Issued To:
 Customer Name : Lala Central School, Hailakandi (Assam)
 Sample Description : Ground Water
 Sample Type : Drinking Water, (Treated)
 Sample collected on dated : 25-11-24
 Sample Collected by : Muazzam Hussain Laskar
 Sample received on dated : 25-11-24
 Sample Location : Vill: Dhanipur, G.P: Tantoo Dhanipur, Hailakandi Assam
 Sample Quantity : 1000 ml
 Date of Analysis started : 25-11-24
 Dated of analysis completed : 26-11-24

RESULTS

Sr. No.	Parameter	Protocol Used	Results	IS: 10500 : 2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Colour	IS 3025: Part 4	<5	5	15	Hazan Units
2	Taste	IS: 3025 (part 8)	Agreeable	Agreeable	Agreeable	
3	Turbidity	IS: 3025 (Part 10)	3	1	5	NTU
4	pH	IS: 3025 (Part 11)	7.47	6.5 – 8.5	No relaxation	pH unit
5	TDS	IS: 3025 (Part 16)	202	500	2000	mg/L
6	Chloride	IS : 3025 (Part 32)	-	250	1000	mg/L
7	Total Alkalinity (as CaCO ₃)	IS: 3025 (Part 23)	46	200	600	mg/L
8	Total Hardness (as CaCO ₃)	IS: 3025 (Part 21)	90	200	600	mg/L
9	Calcium (as Ca)	IS: 3025 (Part 40)	-	75	200	mg/L
10	Magnesium (as Mg)	APHA (24th Ed) 3500 Mg B	-	30	100	mg/L
11	Total Iron (as Fe)	APHA 3500 (24th Ed) Fe B	<0.1	1	No relaxation	mg/L
12	Fluoride (as F)	APHA (24th Ed) 4500-F Method C	<0.1	1	1.5	mg/L
13	Nitrate (as NO ₃)	APHA (24th Ed) 4500 NO ₃ D	3.07	45	No relaxation	mg/L
14	Sulphate (as SO ₃)	IS 3025 (Part 24)	8.22	200	400	mg/L

Notes:

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
- The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: **Subrata Choudhury**

(Name)

Authorized Signatory/Chemist

Lab Name: DLL, HKD

Attested
M. Laskar
 Chairman
 Managing Committee
 Lala Central School
 Hailakandi

END OF TEST REPORT

Attested
Muazzam Hussain Laskar
 Principal
 Lala Central School
 Hailakandi

